

B6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/School/WZ/312

Dated: 7/4/21

FIRE SAFETY CERTIFICATE

Certified that the Building situated at Sachdeva Public School, Sector-13 Rohini, Delhi-110085, comprised of Basement + Ground + 03 upper floors owned/occupied by Sachdeva Public School has already been issued FSC by this department vide letter No. F6/DFS/MS/2017/School/876 dated 19.06.2017. The premises was re-inspected by the officer concerned of this department on 27.02.2021 in the presence of Mr. Raj Parkash Gupta and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy under Educational "Group B" with effect from 7/4/21 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7/4/21 at New Delhi by

(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to :-

1. The Principal, Sachdeva Public School, Sector-13 Rohini, Delhi-110085.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE_Home_Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."


Dr. (Mrs.) RAVIJA PRAKASH
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi


SANJAY SACHDEVA
Manager
Sachdeva Public School
Sector-13, Rohini, Delhi