



DELHI TEST HOUSE[®]

(A Unit of Delhii Test House Global LLP)

A-62/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)

Ph. : +91-11-47075555 (30Lines) E-mail : info@delhitesthouse.com

Website : www.delhitesthouse.com



TC-14461

B8(a)

Report No.: WT250624002

Report Date: 01-Jul-2025

ULR No.: TC1446125000030260F

TEST REPORT

Report issued To :	Sample Received On	Analysis Duration	
		Start Date	End Date
The Principal Sachdeva Public School. Sector-13,Rohoni,Delhi-110085, Delhi, Delhi, 110085	24-Jun-2025	24-Jun-2025	30-Jun-2025

Sample Description :-

Sample Name : Drinking water
Test Reference : IS 10500-2012
Sample Quantity : 2 ltr+250 ml
Customer Letter Ref. No. : SPS(R)/ADMN./2025/2391
Letter Dated : 24.06.2025

Test Results :

Sr.No	Specific Test	Units	Acceptable Limits	Result	Permissible Limits	Test Method
-------	---------------	-------	-------------------	--------	--------------------	-------------

Discipline : CHEMICAL

Main Group : Water

Table-1, Organoleptic and Physical Parameter (Clause 4)

1	Colour	Hazen Unit	Max 5	<2	Max. 15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8)
4	Turbidity	NTU	Max. 1	<1	Max. 5	IS 3025 (P-10)
5	pH Value	-	6.5 to 8.5	7.20	No Relaxation	IS 3025 (P-11)
6	Total Dissolved Solids	mg/l	Max 500	153	Max. 2000	IS 3025 (P-16)

Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)

1	Total Hardness (as CaCO ₃)	mg/l	Max 200	89.1	Max. 600	IS 3025 (P-21)
2	Chloride (as Cl)	mg/l	Max. 250	22.7	Max. 1000	IS 3025 (P-32)
3	Fluoride (as F)	mg/l	Max. 1.0	<0.2	Max. 1.5	APHA.4500F' 24th Edition

Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
-------	---------------	-------	-----	-------------------	--------	--------------------	-------------

Discipline : BIOLOGICAL

Main Group : WATER

Bacteriological test as per Table 6 Clause 4.1.1

1	Total coliform bacteria	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
2	E. coli	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185

Dr. (Mrs.) NAMITA SHARMA
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi

Reviewed By

AJAY KUMAR SINGH

SR. ANALYST

Authorised By

SUMAN KUMAR JHA

QUALITY MANAGER

SANJAY SACHDEVA
M.C. GOEL Manager
Sachdeva Public School
Sector-13, Rohini, Delhi

Authorised Signatory - Director

Report No.: WT250624002

Report Date: 01-Jul-2025

ULR No.: TC1446125000030260F

TEST REPORT



Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
Discipline : CHEMICAL							
Main Group : Residues in Water							
Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)							
1	Iron (as Fe)	mg/l	0.001	Max. 1	BLQ	No Relaxation	IS 3025 (P-65)

BLQ - Below Limit of Quantification

LOQ - Limit of Quantification

Remarks : The sample conforms to IS10500 :2012 with respect to the above test only.

Note : 1. No Deviation from the Standard Test Method/ Specification is done unless specified or requested by the client.
2. While giving the conformity statement laboratory does not consider Uncertainty Measurement into account.
3. General terms & Conditions are given on the back side of the report.





NABL Scope

***** End Of Report *****



Report


Dr. (Mrs.) NAMITA SHARMA
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi


SANJAY SACHDEVA
Manager
Sachdeva Public School
Sector-13, Rohini, Delhi

Reviewed By

Authorised By

M.C. GOEL

B8(b)



MUNICIPAL CORPORATION
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sector 5 Rohini Delhi -110085

Email: dhoroheinizone15@gmail.com Tel: 011-27052106


No.-DHO/RZ/2026/ 85

Date : 07-05-2026


SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed by area Public health Inspector from Public Health department Rohini Zone inspected the **Sachdeva Public School** situated at **Sec-13, Rohini, Delhi-110085** and found that the **Sachdeva Public School**, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.


Dy. Health Officer
Rohini Zone

DIRECTOR
Sachdeva Public School
Sec-13, Rohini, Delhi-110085


Dr. (Mrs.) NAMITA SHARMA
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi


SANJAY SACHDEVA
Manager
Sachdeva Public School
Sector-13, Rohini, Delhi