



TC-14481

Report No.: WT250624002

Report Date: 01-Jul-2025

ULR No.: TC1446125000030260F

## TEST REPORT

Report Issued To :	Sample Received On	Analysis Duration	
		Start Date	End Date
The Principal Sachdeva Public School. Sector-13,Rohoni,Delhi-110085, Delhi, Delhi, 110085	24-Jun-2025	24-Jun-2025	30-Jun-2025

### Sample Description :-

Sample Name : Drinking water  
Test Reference : IS 10500-2012  
Sample Quantity : 2 ltr+250 ml  
Customer Letter Ref. No. : SPS(R)/ADMN./2025/2391  
Letter Dated : 24.06.2025

### Test Results :

Sr.No	Specific Test	Units	Acceptable Limits	Result	Permissible Limits	Test Method
-------	---------------	-------	-------------------	--------	--------------------	-------------

#### Discipline : CHEMICAL

#### Main Group : Water

#### Table-1, Organoleptic and Physical Parameter (Clause 4)

1	Colour	Hazen Unit	Max 5	<2	Max. 15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8)
4	Turbidity	NTU	Max. 1	<1	Max. 5	IS 3025 (P-10)
5	pH Value	-	6.5 to 8.5	7.20	No Relaxation	IS 3025 (P-11)
6	Total Dissolved Solids	mg/l	Max 500	153	Max. 2000	IS 3025 (P-16)

#### Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)

1	Total Hardness (as CaCO <sub>3</sub> )	mg/l	Max 200	89.1	Max. 600	IS 3025 (P-21)
2	Chloride (as Cl)	mg/l	Max. 250	22.7	Max. 1000	IS 3025 (P-32)
3	Fluoride (as F)	mg/l	Max. 1.0	<0.2	Max. 1.5	APHA.4500F' 24th Edition

Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
-------	---------------	-------	-----	-------------------	--------	--------------------	-------------

#### Discipline : BIOLOGICAL

#### Main Group : WATER

#### Bacteriological test as per Table 6 Clause 4.1.1

1	Total coliform bacteria	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
2	E. coli	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185

Reviewed By

Authorised By

M.C. GOEL

DR. (MRS.) RAVIJA PRAKASH

SANJAY SACHDEVA

Authorised Signatory - Director

Page 1 Of 2

Principal

Sachdeva Public School  
Sector-13, Rohini, Delhi-85

AJAY KUMAR SINGH

SUMAN KUMAR JHA

SR. ANALYST

QUALITY MANAGER

BRANCH OFFICES ALL ACROSS INDIA

QR-0302





Report No.: WT250624002

Report Date: 01-Jul-2025

ULR No.: TC1446125000030260F

## TEST REPORT

Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
<b>Discipline : CHEMICAL</b>							
<b>Main Group : Residues in Water</b>							
<b>Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)</b>							
1	Iron (as Fe)	mg/l	0.001	Max. 1	BLQ	No Relaxation	IS 3025 (P-65)

BLQ - Below Limit of Quantification

LOQ - Limit of Quantification

**Remarks** : The sample conforms to IS10500 :2012 with respect to the above test only.

**Note** :

1. No Deviation from the Standard Test Method/ Specification is done unless specified or requested by the client.
2. While giving the conformity statement laboratory does not consider Uncertainty Measurement into account.
3. General terms & Conditions are given on the back side of the report.



NABL Scope

\*\*\*\*\* End Of Report \*\*\*\*\*



Report

*[Signature]*  
**DR. (MRS.) RAVIJA PRAKASH**  
Principal  
Sachdeva Public School  
Sector-13, Rohini, Delhi-85

*[Signature]*  
**SANJAY SACHDEVA**  
Manager  
Sachdeva Public School  
Sector-13, Rohini, Delhi

Reviewed By

Authorised By

M.C. GOEL





MUNICIPAL CORPORATION  
(Office of Dy. Health Officer: Rohini Zone)  
Public Health Department  
Sector 5 Rohini Delhi -110085  
Email: [dhoroheinizone15@gmail.com](mailto:dhoroheinizone15@gmail.com) Tel: 011-27052106


No.-DHO/RZ/2025/ 328

Date : 26.06.2025

**SCHOOL HEALTH CERTIFICATE**


It is certified that an inspection team headed by area Public health Inspector from Public Health department Rohini Zone inspected the **Sachdeva Public School at Sec-13, Rohini, Delhi-110085** and found that the **Sachdeva Public School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of 31-03-2026.

  
26/6/25  
Dy. Health Officer  
Rohini Zone  
Deputy Health Officer  
Municipal Corporation of Delhi  
Rohini Zone

**PRINCIPAL**  
**Sachdeva Public School**  
**Sec-13, Rohini,**  
**Delhi-110085**

  
DR. (MRS.) RAVIJA PRAKASH  
Principal  
Sachdeva Public School  
Sector-13, Rohini, Delhi-85

  
SANJAY SACHDEVA  
Manager  
Sachdeva Public School  
Sector-13, Rohini, Delhi